QEP 3.5 50Hz 1p

QEP Range




Genset Image for illustration purposes only

| Power ratings | | | | |
|---------------|-------|---------|---------|--|
| Prime | Prime | Standby | Standby | |
| kW | kVA | kW | kVA | |
| 2.6 | 2.9 | 3.1 | 3.4 | |
| Power facto | or | | 0.9 | |


Fuel consumption table

| Load level | PRIME | Aut. (h) |
|------------|-------|----------|
| | (L/h) | |
| 75% | 1.18 | 9.32 |
| 100% | 1.57 | 7.01 |



| Mechanical structure | | | |
|----------------------|------|----------|--|
| Length (L) | (mm) | 623 | |
| Width (W) | (mm) | 409 | |
| Height (H) | (mm) | 500 | |
| Weight | (kg) | 43 | |
| Fuel tank capacity | (1) | 11 | |
| Wheels and handles | | Optional | |

Dimensions



Note: These drawings are provided for illustration purposes only.

Engine

| General | | | |
|------------------|-------|----------|--|
| Engine Brand | | Honda | |
| Engine Model | | GX200 | |
| R.P.M. | | 3000 | |
| Net Power | (kWm) | 3.80 | |
| Fuel | | Gasoline | |
| No. of cylinders | | 1 | |
| Displacement | (cm³) | 196 | |
| Regulation type | | Mechanic | |

| L | brication System | |
|------------------|------------------|-----|
| Oil capacity | (1) | 0.6 |
| Engine Oil Guard | | YES |
| | | |

| Cooling Sy | ystem |
|--------------|-------|
| Cooling type | Air |

| Starting syst | tem |
|---------------|-----|
| Recoil | YES |
| Electric 12V | NO |

Alternator

| Alternator brand | | NSM |
|-----------------------------|-------|------------------------|
| Alternator model | | K80E |
| IP alternator | | IP23 |
| Peak power 163°/27° | (kVA) | 3.24 |
| Poles | | 2 |
| Excitation system | | Capacitor Brushless |
| Efficiency at 100% 125°/40° | (%) | 71 |

1633103178

Please, contact your local Atlas Copco Dealer for more information

QEP 3.5 50Hz 1p2014EN1.0



Mains features and options

Mains features

- Recoil start
- Large fuel tank
- Engine Oil Guard
- Protective top cover
- Thermal protection
- Fuel Cock

Sockets configuration

SCHUKO 230V 16A IP54

• CE noise compliance

Sockets

2

Options

- Wheel kit
- Automatic Voltage Regulation (AVR)
- Differential circuit breaker, hourmeter (ELR)

Regulations:

The generator set has a CE Marking that includes the following directives:

- 2006/42/CE Machine Safety.
- 2006/95/CEE Low Voltage.
- 2004/108/CE Electromagnetic compatibility.
- 97/68/CE Gases and contaminating particles emissions.
- 2005/88/CE Noise emission in the environment by equipment for use outdoors.

Definitions

Prime Rating

PRIME POWER: Electrical power data available at a variable load without limits of hours per year. An overload of 10 % is allowed for 1 hour of every 12. In accordance with ISO 8528/1 (2005) – PRP

Standby

STANDBY POWER: Electrical power data at variable load in an emergency in accordance with standard ISO 8528/1 (2005) – ESP. Overloads of emergency power are not allowed.

 $\textit{Grupos Electr\'ogenos Europa, S.A. is a certified company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL Company and PECAL Company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL COMPANY AND ADMINISTRATION OF THE PECAL COMPANY AND ADMINISTRA$

Atlas Copco reserves the right to modify any characteristic of their equipment without prior warning. All products are designed and engineered in Zaragoza Competence Center

Weight and dimensions of a standard generator set.

Non-contractual document

Grupos Electrógenos Europa, S.A. Central Offices:

Polígono pitarco II - Parcela 20 50450 Muel (Zaragoza) España

Tel.: +34 976 145 432 Fax.: +34 976 145 431

| DISTRIBUTED BY: | |
|-----------------|--|
| | |

Please, contact your local Atlas Copco Dealer for more information

QEP 3.5 50Hz 1p2014EN1.0

