QEP 6 50Hz 1p

QEP Range




Genset Image for illustration purposes only

Technical data		
Voltage	(V)	230
Frequency	(Hz)	50
Fuel		Diesel
Performance class		G1
Acoustic pressure LpA	(dB(A) @7m)	-
Acoustic power LwA	(dB(A))	-

Mechanical structure		
Length (L)	(mm)	760
Width (W)	(mm)	540
Height (H)	(mm)	560
Weight	(kg)	94
Fuel tank capacity	(I)	5.5
Wheels and handles		Optional

Dimensions



Note: These drawings are provided for illustration purposes only.

Engine

-			
	General		
Engine Brand			Yanmar
Engine Model			L100
R.P.M.			3000
Net Power		(kWm)	6.50
Fuel			Diesel
No. of cylinders			1
Displacement		(cm³)	435
Regulation type			Mechanic
Regulation type			Wethanit

Lubrication	n System	
Oil capacity	(1)	1.6
Engine Oil Guard		YES

	Cooling System	
Cooling type		Air

1633103212

Please, contact your local Atlas Copco Dealer for more information

	Pow	er ratings	
Prime	Prime	Standby	Standby
kW	kVA	kW	kVA
4.4	4.9	5.3	5.9
Power facto	or		0.9

Fuel consumption table

Load level	PRIME	Aut. (h)
	(L/h)	
75%	1.45	3.79
100%	1.94	2.84

Starting system	
Recoil	YES
Electric 12V	NO

Alternator

Alternator brand		Mecc Alte
Alternator model		S16W 130/A
IP alternator		IP23
Peak power 163°/27°	(kVA)	5.4
Poles		2
Excitation system		Capacitor
		Brushless
Efficiency at 100% 125°/40°	(%)	77

QEP 6 50Hz 1p2014EN1.0



Mains features and options

Mains features

Recoil startFuel Cock

Engine Oil Guard

- Engline On Oddre

Sockets

Sockets configuration	
SCHUKO 230V 16A IP54	1
2P+T CEE 230V 32A IP44	1

Options

• Wheel kit

• Differential circuit breaker, hourmeter (ELR)

Regulations:

The generator set has a CE Marking that includes the following directives:

■ 2006/42/CE Machine Safety.

■ 2006/95/CEE Low Voltage.

■ 2004/108/CE Electromagnetic compatibility.

Definitions

Prime Rating

PRIME POWER: Electrical power data available at a variable load without limits of hours per year. An overload of 10 % is allowed for 1 hour of every 12. In accordance with ISO 8528/1 (2005) – PRP

Standby

1633103212

STANDBY POWER: Electrical power data at variable load in an emergency in accordance with standard ISO 8528/1 (2005) – ESP. Overloads of emergency power are not allowed.

Grupos Electrógenos Europa, S.A. is a certified company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL Atlas Copco reserves the right to modify any characteristic of their equipment without prior warning. All products are designed and engineered in Zaragoza Competence Center Weight and dimensions of a standard generator set. Non-contractual document

Grupos Electrógenos Europa, S.A. Central Offices: Polígono pitarco II - Parcela 20 50450 Muel (Zaragoza) España Tel.: +34 976 145 432 Fax.: +34 976 145 431 DISTRIBUTED BY:

Please, contact your local Atlas Copco Dealer for more information

QEP 6 50Hz 1p2014EN1.0

