QEP R7 50Hz 3p AVR ITR 12V

QEP Range



Genset Image for illustration purposes only

Technical data			
Voltage	(V)	400	
Frequency	(Hz)	50	
Fuel		Diesel	
Performance class		G1	
Acoustic pressure LpA	(dB(A) @7m)	-	
Acoustic power LwA	(dB(A))	-	

Mechanic	al structure	
Length (L)	(mm)	840
Width (W)	(mm)	641
Height (H)	(mm)	696
Weight	(kg)	124
Fuel tank capacity	(I)	24
Wheels and handles		Optional

Dimensions



Note: These drawings are provided for illustration purposes only.

Engine

-			
	General		
Engine Brand			Yanmar
Engine Model			L100
R.P.M.			3000
Net Power		(kWm)	6.50
Fuel			Diesel
No. of cylinders			1
Displacement		(cm³)	435
Regulation type			Mechanic

Lubrication	n System	
Oil capacity	(I)	1.6
Engine Oil Guard		YES

	Cooling System	
Cooling type		Air

1633103233

Please, contact your local Atlas Copco Dealer for more information

	Pow	er ratings	
Prime	Prime	Standby	Standby
kW	kVA	kW	kVA
4.5	5.6	5.5	6.9
Power facto	or		0.8

Fuel consumption table

Load level	PRIME	Aut. (h)
	(L/h)	
75%	1.45	16.55
100%	1.94	12.37

Starting s	ystem
Recoil	NO
Electric 12V	YES

Alternator

Alternator brand		NSM
Alternator model		T100SB
IP alternator		IP23
Peak power 163°/27°	(kVA)	6.48
Poles		2
Excitation system		Compound
		Brushless
Efficiency at 100% 125°/40°	(%)	79

QEP R7 50Hz 3p AVR ITR 12V2014EN2.0



Mains features and options

Mains features

Iviality realures	
 Electrical key start (12V) 	 Insulation monitoring relay (ITR)
 Large fuel tank 	• Sockets
 Engine Oil Guard 	
 Automatic Voltage Regulation (AVR) 	
 Thermal protection 	
 Instrumentation, voltmeter, hourmeter 	
Sockets configuration	
SCHUKO 230V 16A IP54	1
2P+T CEE 230V 16A IP44	2
3P+N+T CEE 400V 16A IP44	1
Options	

Wheel kit

Regulations:

The generator set has a CE Marking that includes the following directives:

- 2006/42/CE Machine Safety.
- 2006/95/CEE Low Voltage.
- 2004/108/CE Electromagnetic compatibility.

Definitions

Prime Rating

PRIME POWER: Electrical power data available at a variable load without limits of hours per year. An overload of 10 % is allowed for 1 hour of every 12. In accordance with ISO 8528/1 (2005) – PRP

Standby

1633103233

STANDBY POWER: Electrical power data at variable load in an emergency in accordance with standard ISO 8528/1 (2005) – ESP. Overloads of emergency power are not allowed.

Grupos Electrógenos Europa, S.A. is a certified company with ISO 9001, ISO 14001, OHSAS 18001 and PECAL Atlas Copco reserves the right to modify any characteristic of their equipment without prior warning. All products are designed and engineered in Zaragoza Competence Center Weight and dimensions of a standard generator set. Non-contractual document

Grupos Electrógenos Europa, S.A.
Central Offices:
Polígono pitarco II - Parcela 20
50450 Muel (Zaragoza) España
Tel.: +34 976 145 432
Fax.: +34 976 145 431

DISTRIBUTED BY:

Please, contact your local Atlas Copco Dealer for more information

QEP R7 50Hz 3p AVR ITR 12V2014EN2.0

